

ਦਫਤਰ ਨਗਰ ਕੌਂਸਲ, ਫਾਜ਼ਿਲਕਾ (ਜਿਲ੍ਹਾ ਫਾਜ਼ਿਲਕਾ)

ਵੱਲੋਂ,

ਕਾਰਜ ਸਾਧਕ ਅਫਸਰ
ਨਗਰ ਕੌਂਸਲ ਫਾਜ਼ਿਲਕਾ।

ਵੱਲੋਂ:

Dayanand Chanan Lal
DAV Public School,
Civil Lines, Fazilka.

ਨੰ: 560

ਮਿਤੀ: 2/4/2024

ਵਿਸ਼ਾ:- ਸੈਨੀਟੇਸ਼ਨ ਸਰਟੀਫਿਕੇਟ ਸਬੰਧੀ।

ਹਵਾਲਾ:- ਆਪ ਦਾ ਪੱਤਰ ਨੰ: DCDAVFZK451 ਮਿਤੀ: 05-03-2024 ਦੇ ਸਬੰਧ ਵਿੱਚ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਤੇ ਹਵਾਲੇ ਅਧੀਨ ਪੱਤਰ ਦੇ ਸਬੰਧ ਵਿੱਚ ਆਪ ਨੂੰ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਆਪ ਦੇ ਸਕੂਲ ਵਲੋਂ ਜੋ ਸਫਾਈ ਵਿਵਸਥਾ ਦਾ ਕੰਮ ਕੀਤਾ ਜਾ ਰਿਹਾ ਹੈ, ਉਹ ਤਸੱਲੀਬਖਸ਼ ਹੈ।

ਕਾਰਜ ਸਾਧਕ ਅਫਸਰ
ਨਗਰ ਕੌਂਸਲ ਫਾਜ਼ਿਲਕਾ
ਨ

DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawali, Fazilka
dwtlfazilka@gmail.com

To,

Dayanand Chanan Lal DAV Public School, Civil Lines, Old SDM Court Road Fazilka (Pb)152123

No.: DWTL/FZK/2324/00197 Dated : 18/03/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. DCDAVFzk/452 Dated: 05/03/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 08/03/2024. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Fazilka

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory
Fazilka

DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawali, Fazilka
dwtlfazilka@gmail.com

TEST REPORT						
Name & Address of Customer : Dayanand Chanan Lal DAV Public School,Civil Lines,Old SDM Court Road Fazilka (Pb)152123			Customer Reference No.:		No : DCDAVFzk/452 Dated : 05/03/2024	
			Sample Submitted by		Sh.Vishal Babbar	
			Date of Sample Receipt		08/03/2024	
			Analysis Starting Date		12/03/2024	
			Analysis completion Date		13/03/2024	
Discipline : Chemical Testing			Group: Water			
ULR No.:			Sample Type :		Water	
Test Report No.:			Date of Issue :		18/03/2024	
Registration no.:			Condition of Sample :		Unsealed	
Collection Point:			Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:			Location/Depth :		Dayanand Chanan Lal DAV Public School,Civil Lines,Old SDM Court Road Fazilka (Pb)152123 / NA	
Village :			Habitation :		Not Mentioned	
Block:			District :		Fazilka	
Latitude :			Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.03	6.5-8.5	No Relaxation		IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	-	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	-	IS 3025 (Part 8 – 2023)
5	TDS	103	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	76	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	36	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	3	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	6	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B. By Calculation Method

DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawali, Fazilka
dwtlfazilka@gmail.com

11	Chloride	22	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---

Note: Detection Limit(Turbidity:0.5,)

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter
6. Temperature condition limit: 25+5°C and Humidity condition limit:50 +20%

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Fazilka

----- End of the Test Report -----