

# DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawali, Fazilka  
dwtfzailka@gmail.com




TC-10083

## TEST REPORT

Name & Address of Customer : <b>Dayanand Chanan Lal DAV Public School</b> <b>ayanand Chanan Lal DAV Public School</b>		Customer Reference No.	No : DCDAVFZK/285 Dated : 01/09/2022			
		Sample Submitted by	Sh. Neki Ram			
		Date of Sample Receipt	01/09/2022			
		Analysis Starting Date	01/09/2022			
		Analysis completion Date	02/09/2022			
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>				
Test Report No.:	DWTL/FZK/2223/00051	Date of Issue :	06/09/2022			
Registration no.:	DWTL/FZK/REG2223/00161	Condition of Sample :	Unsealed			
Source :	NA	Quantity/Type of Bottle:	1000 ml / Plastic Bottles			
Scheme :	NA	Location/Depth :	Dayanand Chanan Lal DAV Public School Fazilka / NA			
Village :	NA	Habitation :	NA			
Block:	NA	District :	Fazilka			
Latitude :	NA	Longitude:	NA			
Sample Type: <b>Water</b>						
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.83	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993 ) Electrometric Method
2	Colour	1	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Disagreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	254	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.01	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	72	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	80	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	48	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	9	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	59	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. \* Value not available or test not performed for this parameter.



**Mr. Pardeep kumar**  
Quality Manager  
Authorized Signatory  
For, District water Testing Laboratory,  
Fazilka

# DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawali, Fazilka  
dwtlfazilka@gmail.com



----- End of the Test Report -----

## DISTRICT WATER TESTING LABORATORY, FAZILKA

Village Panchawali, Fazilka  
dwtfazilka@gmail.com

To,

Dayanand Chanan Lal DAV Public School  
ayanand Chanan Lal DAV Public School

No.: DWTL/FZK/2223/00051 Dated : 06/09/2022

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. DCDAVFZK/285 Dated: 01/09/2022

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 01/09/2022. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Fazilka

D/A : Test Report



Authorized Signatory  
For, District water Testing Laboratory, Fazilka



# ਦਫਤਰ ਨਗਰ ਕੌਂਸਲ, ਫਾਜ਼ਿਲਕਾ (ਜਿਲ੍ਹਾ ਫਾਜ਼ਿਲਕਾ)

---

ਵੱਲ,

ਕਾਰਜ ਸਾਧਕ ਅਫਸਰ  
ਨਗਰ ਕੌਂਸਲ ਫਾਜ਼ਿਲਕਾ।

ਵੱਲ:

Dayanand Chanan Lal  
DAV Public School,  
Civil Lines, Fazilka.

ਨੰ: 1988

ਮਿਤੀ: 5/9/2022

ਵਿਸ਼ਾ:- ਸੈਨੀਟੇਸ਼ਨ ਸਰਟੀਫਿਕੇਟ ਸਬੰਧੀ।

ਹਵਾਲਾ:- ਆਪ ਦਾ ਪੱਤਰ ਨੰ: 286 ਮਿਤੀ: 02-09-2022 ਦੇ ਸਬੰਧ ਵਿੱਚ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਤੇ ਹਵਾਲੇ ਅਧੀਨ ਪੱਤਰ ਦੇ ਸਬੰਧ ਵਿੱਚ ਆਪ ਨੂੰ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਆਪ ਦੇ ਸਕੂਲ ਵਲੋਂ ਜੋ ਸਫਾਈ ਵਿਵਸਥਾ ਦਾ ਕੰਮ ਕੀਤਾ ਜਾ ਰਿਹਾ ਹੈ, ਉਹ ਤਸੱਲੀਬਖਸ਼ ਹੈ।

ਕਾਰਜ ਸਾਧਕ ਅਫਸਰ  
ਨਗਰ ਕੌਂਸਲ ਫਾਜ਼ਿਲਕਾ

**ENGLISH VERSION**

**Office of Muncipal Council Fazilka (Disst Fazilka)**

From

Work improvement Officer

Municipal Council, Fazilka

Ref no. 1988

Dated 05-09-2022

To,

Principal

Dayanand Chanan Lal Public School

Civil Line Old SDM Court Road

Fazilka - 152123

**Subject:- Sanitation Certificate Regarding.**

Reference your letter no.286 dated 02-09-2022.

In reference to above cited subject and letter it is certified that sanitation arrangement of the school is satisfactory.

Sd/-

Works improvements officer

Municipal Council, Fazilka



Principa

Dayanand Chanan Lal D A. V Public Scho-

FAZILKA